

SUCURSALA OLTENITA



Partenerul familiei tale

STR. TINERETULUI 159 + 161 TEL / FAX: 0242-515.736 E-mail:

ecoaquaoltenita@yahoo.com

Nr.: 6499 / 20.10.2025

SC ECOAQUA S.A. CALARASI

SUCURSALA OLTENITA

DATA 13.10.2025

PUNCT DE RECOLTARE_IESIRE STATIE SOLDANU

BULETIN DE ANALIZE CHIMICE SI BACTERIOLOGICE APA POTABILA

	Parametrii	UM	Valori CMA	Valori medii zilnice
1	Temperatura	°C		-
2	Clor rezidual, total si liber	mg/l	0.5	0.48
3	Amoniu	mg/l	0.5	ABS
4	Aluminii	µg/l	200	-
5	Conductivitate	µS cm ⁻¹	2500	-
6	Cloruri	mg/l	250	63.9
7	Duritate totala	°G	Min. 5	24.8
8	Fier total	µg/l	200	30
9	Nitrati	mg/l	50	15.91
10	Nitriti	mg/l	0.5	ABS
11	Oxidabilitate	Mg O ₂ /l	5	1.27
12	pH	Unit. Ph	6.5-9.5	7.21
13	Mangan	µg/l	50	35
14	Sulfuri si hidrogen sulfurat	µg/l	100	-
15	Turbiditate	UNT	1-apa adancime 5-apa suprafata	0.40
16	Culoare, gust, miros	Acceptabila consumatorilor si nici o modificare anormala		-
17	Nr. de colonii la 22°C	Nr./100ml	nici o modificare anormala	-
18	Nr. de colonii la 37°C	Nr./100ml	nici o modificare anormala	0
19	Coliformi	Nr./100ml	0	0
20	Escherichia coli	Nr./100ml	0	0
21	Enterococi	Nr./100ml	0	0

Concluzii: 0

PROBA ~~NE~~ CORESPUNZATOARE DPDV FIZICO CHIMICPROBA ~~NE~~ CORESPUNZATOARE DPDV BACTERIOLOGIC

CONFORM Ordonantei 7/2023 privind calitatea apei destinata consumului uman

SEF LABORATOR,

BIOLOG,
GURESOAE IRINA

DIRECTOR SUCURSALA,

IVANCIU MONA