

SUCURSALA OLTENITA

STR. TINERETULUI 159 ÷ 161 TEL / FAX: 0242-515.736 E-mail:
ecoaquaoltenita@yahoo.com

Nr.: 6804 120.10.2025

SC ECOAQUA S.A. CALARASI

SUCURSALA OLTENITA

DATA 29.09.2025

PUNCT DE RECOLTARE lesire statie Spantov

BULETIN DE ANALIZE CHIMICE SI BACTERIOLOGICE APA POTABILA

	Parametrii	UM	Valori CMA	Valori medii zilnice
1	Temperatura	°C		-
2	Clor rezidual, total si liber	mg/l	0.5	0.1
3	Amoniu	mg/l	0.5	ABS
4	Aluminiu	µg/l	200	-
5	Conductivitate	µS cm ⁻¹	2500	-
6	Cloruri	mg/l	250	53.21
7	Duritate totala	°G	Min. 5	18.38
8	Fier total	µg/l	200	20
9	Nitrati	mg/l	50	30.49
10	Nitriti	mg/l	0.5	ABS
11	Oxidabilitate	Mg O ² /l	5	0.87
12	pH	Unit. Ph	6.5-9.5	7.26
13	Mangan	µg/l	50	19
14	Sulfuri si hidrogen sulfurat	µg/l	100	-
15	Turbiditate	UNT	1-apa adancime 5-apa suprafata	0.31
16	Culoare, gust, miros	Acceptabila consumatorilor si nici o modificare anormaia		-
17	Nr. de colonii la 22°C	Nr./100ml	nici o modificare anormala	-
18	Nr. de colonii la 37°C	Nr./100ml	nici o modificare anormala	16
19	Coliformi	Nr./100ml	0	0
20	Escherichia coli	Nr./100ml	0	0
21	Enterococi	Nr./100ml	0	0

Concluzii:

PROBA ~~NE~~-CORESPUNZATOARE DPDV FIZICO CHIMIC

PROBA ~~NE~~-CORESPUNZATOARE DPDV BACTERIOLOGIC

CONFORM Ordonantei 7/2023 privind calitatea apei destinata consumului uman

SEF LABORATOR,

BIOLOG,

Guresoae Irina

DIRECTOR SUCURSALA,

IVANCIU MONA