

SUCURSALA OLTENIȚA

STR. TINERETULUI 159 ÷ 161 TEL / FAX: 0242-515.736 E-mail:

ecoaquaoltenita@yahoo.com

Nr.: _____ / _____

SC ECOAQUA S.A. CALARASI

SUCURSALA OLTENITA

DATA 18.11..2025

PUNCT DE RECOLTARE_ IESIRE STATIE SOLDANU

BULETIN DE ANALIZE CHIMICE SI BACTERIOLOGICE APA POTABILA

	Parametrii	UM	Valori CMA	Valori medii zilnice
1	Temperatura	°C		-
2	Clor rezidual, total si liber	mg/l	0.5	0.32
3	Amoniu	mg/l	0.5	Abs
4	Aluminiu	µg/l	200	-
5	Conductivitate	µS cm ⁻¹	2500	-
6	Cloruri	mg/l	250	56.8
7	Duritate totala	°G	Min. 5	25.56
8	Fier total	µg/l	200	80
9	Nitrati	mg/l	50	15.91
10	Nitriti	mg/l	0.5	Abs
11	Oxidabilitate	Mg O ² /l	5	1.19
12	pH	Unit. Ph	6.5-9.5	7.34
13	Mangan	µg/l	50	32
14	Sulfuri si hidrogen sulfurat	µg/l	100	-
15	Turbiditate	UNT	1-apa adancime 5-apa suprafata	0.30
16	Culoare, gust, miros	Acceptabila consumatorilor si nici o modificare anormala		-
17	Nr. de colonii la 22°C	Nr./100ml	nici o modificare anormala	-
18	Nr. de colonii la 37°C	Nr./100ml	nici o modificare anormala	4
19	Coliformi	Nr./100ml	0	0
20	Escherichia coli	Nr./100ml	0	0
21	Enterococi	Nr./100ml	0	0

Concluzii:

PROBA ~~NE~~-CORESPUNZATOARE DPDV FIZICO CHIMIC

PROBA ~~NE~~-CORESPUNZATOARE DPDV BACTERIOLOGIC

CONFORM ORDONANTEI 7/2022

BIOLOG,
Guresoae Irina

DIRECTOR,

SUCURSALA OLTENIȚA

STR. TINERETULUI 159 ÷ 161 TEL / FAX: 0242-515.736 E-mail:

ecoaquaoltenita@yahoo.com

Nr.: _____ / _____

SC ECOAQUA S.A. CALARASI

SUCURSALA OLTENITA

DATA 10.12..2025

PUNCT DE RECOLTARE_ IESIRE STATIE SOLDANU

BULETIN DE ANALIZE CHIMICE SI BACTERIOLOGICE APA POTABILA

	Parametrii	UM	Valori CMA	Valori medii zilnice
1	Temperatura	°C		-
2	Clor rezidual, total si liber	mg/l	0.5	0.25
3	Amoniu	mg/l	0.5	Abs
4	Aluminiu	µg/l	200	-
5	Conductivitate	µS cm ⁻¹	2500	-
6	Cloruri	mg/l	250	63.9
7	Duritate totala	°G	Min. 5	24.80
8	Fier total	µg/l	200	30
9	Nitrati	mg/l	50	15.91
10	Nitriti	mg/l	0.5	Abs
11	Oxidabilitate	Mg O ² /l	5	1.27
12	pH	Unit. Ph	6.5-9.5	7.21
13	Mangan	µg/l	50	35
14	Sulfuri si hidrogen sulfurat	µg/l	100	-
15	Turbiditate	UNT	1-apa adancime 5-apa suprafata	0.40
16	Culoare, gust, miros	Acceptabila consumatorilor si nici o modificare anormala		-
17	Nr. de colonii la 22°C	Nr./100ml	nici o modificare anormala	-
18	Nr. de colonii la 37°C	Nr./100ml	nici o modificare anormala	1
19	Coliformi	Nr./100ml	0	0
20	Escherichia coli	Nr./100ml	0	0
21	Enterococi	Nr./100ml	0	0

Concluzii:

PROBA ~~NE~~-CORESPUNZATOARE DPDV FIZICO CHIMIC

PROBA ~~NE~~-CORESPUNZATOARE DPDV BACTERIOLOGIC

CONFORM ORDONANTEI 7/2022

BIOLOG,
Guresoae Irina

DIRECTOR,