

## SUCURSALA OLTENITA

STR. TINERETULUI 159 ÷ 161 TEL / FAX: 0242-515.736 E-mail:  
[ecoquaoltenita@yahoo.com](mailto:ecoquaoltenita@yahoo.com)

Nr.: 4231 / 11.06.2026

SC ECOAQUA S.A. CALARASI

SUCURSALA OLTENITA

DATA 26.05.2026

PUNCT DE RECOLTARE\_IESIRE STATIE DOROBANTU (PLATARESTI)

### BULETIN DE ANALIZE CHIMICE SI BACTERIOLOGICE APA POTABILA

|    | Parametrii                    | UM                                                          | Valori CMA                        | Valori medii zilnice |
|----|-------------------------------|-------------------------------------------------------------|-----------------------------------|----------------------|
| 1  | Temperatura                   | °C                                                          |                                   | -                    |
| 2  | Clor rezidual, total si liber | mg/l                                                        | 0.5                               | 0.14                 |
| 3  | Amoniu                        | mg/l                                                        | 0.5                               | 0.48                 |
| 4  | Aluminiu                      | µg/l                                                        | 200                               | -                    |
| 5  | Conductivitate                | µS cm <sup>-1</sup>                                         | 2500                              | -                    |
| 6  | Cloruri                       | mg/l                                                        | 250                               | 31.95                |
| 7  | Duritate totala               | °G                                                          | Min. 5                            | 4.48                 |
| 8  | Fier total                    | µg/l                                                        | 200                               | 47                   |
| 9  | Nitrati                       | mg/l                                                        | 50                                | abs                  |
| 10 | Nitriti                       | mg/l                                                        | 0.5                               | abs                  |
| 11 | Oxidabilitate                 | Mg O <sup>2</sup> /l                                        | 5                                 | 1.91                 |
| 12 | pH                            | Unit. Ph                                                    | 6.5-9.5                           | 7.45                 |
| 13 | Mangan                        | µg/l                                                        | 50                                | 35                   |
| 14 | Sulfuri si hidrogen sulfurat  | µg/l                                                        | 100                               | -                    |
| 15 | Turbiditate                   | UNT                                                         | 1-apa adancime<br>5-apa suprafata | 0.34                 |
| 16 | Culoare, gust, miros          | Acceptabila consumatorilor si nici o<br>modificare anormala |                                   | -                    |
| 17 | Nr. de colonii la 22°C        | Nr./100ml                                                   | nici o modificare<br>anormala     | -                    |
| 18 | Nr. de colonii la 37°C        | Nr./100ml                                                   | nici o modificare<br>anormala     | 1                    |
| 19 | Coliformi                     | Nr./100ml                                                   | 0                                 | 0                    |
| 20 | Escherichia coli              | Nr./100ml                                                   | 0                                 | 0                    |
| 21 | Enterococi                    | Nr./100ml                                                   | 0                                 | 0                    |

#### Concluzii:

PROBA NE-CORESPUNZATOARE DPDV FIZICO CHIMIC

PROBA NE-CORESPUNZATOARE DPDV BACTERIOLOGIC

CONFORM Ordonantei 7/2023 privind calitatea apei destinata consumului uman

SEF LABORATOR,



BIOLOG,

Guresoae Irina  


DIRECTOR SUCURSALA,

EC. STATE LAURENTIU

