

SUCURSALA OLTENITA

STR. TINERETULUI 159 ÷ 161 TEL / FAX: 0242-515.736 E-mail:
ecoaquaoltenita@yahoo.com

Nr.: 5896 / 10.08.2026

SC ECOAQUA S.A. CALARASI

SUCURSALA OLTENITA

DATA 25.07.2026

PUNCT DE RECOLTARE_IESIRE STATIE OLTENITA

BULETIN DE ANALIZE CHIMICE SI BACTERIOLOGICE APA POTABILA

	Parametrii	UM	Valori CMA	Valori medii zilnice
1	Temperatura	°C		17
2	Clor rezidual, total si liber	mg/l	0.5	0.5
3	Amoniu	mg/l	0.5	Abs
4	Aluminiu	µg/l	200	-
5	Conductivitate	µS cm ⁻¹	2500	-
6	Cloruri	mg/l	250	92.3
7	Duritate totala	°G	Min. 5	17.71
8	Fier total	µg/l	200	130
9	Nitrati	mg/l	50	Abs
10	Nitriti	mg/l	0.5	Abs
11	Oxidabilitate	Mg O ² /l	5	1.19
12	pH	Unit. Ph	6.5-9.5	7.41
13	Mangan	µg/l	50	19
14	Sulfuri si hidrogen sulfurat	µg/l	100	-
15	Turbiditate	UNT	1-apa adancime 5-apa suprafata	0.30
16	Culoare, gust, miros	Acceptabila consumatorilor si nici o modificare anormala		-
17	Nr. de colonii la 22°C	Nr./100ml	nici o modificare anormala	-
18	Nr. de colonii la 37°C	Nr./100ml	nici o modificare anormala	1
19	Coliformi	Nr./100ml	0	0
20	Escherichia coli	Nr./100ml	0	0
21	Enterococi	Nr./100ml	0	0

Concluzii:

PROBA NE-CORESPUNZATOARE DPDV FIZICO CHIMIC

PROBA NE-CORESPUNZATOARE DPDV BACTERIOLOGIC

CONFORM Ordonantei 7/2023 privind calitatea apei destinata consumului uman

SEF LABORATOR,



BIOLOG,

Guresoae Irina



DIRECTOR SUCURSALA,

